

TENDER NOTICE

Sealed Bids are invited from reputable quality firms/suppliers **registered with GST Deptt. and must be on active tax payer list (ATL)** for supply of **UPS (10 KVA)** for International Islamic University, Islamabad:

2. Tender documents can be downloaded from **www.ppra.org.pk** and **www.iiu.edu.pk**. Tender fee of Rs.500/- each (Non-refundable) will be deposited alongwith bid/tender in the shape of Call Deposit/Bank Draft in favour of IIUI.

3. Tenders valid for a period of 03 months on F.O.R. basis along-with earnest money @ 2% of the total value of tender (refundable) in the shape of Call Deposit/Bank Draft in the name of International Islamic University, Islamabad, must reach the undersigned on or before **21-03-2017 at 10:30 a.m.** which will be opened on the same date at **11:00 a.m.** in the presence of the bidders/their representatives who may like to attend the opening ceremony. The GST Registration No. issued by the Sales Tax Department must be mentioned in the bid, otherwise, tender shall not be considered. Price quoted must inclusive of General Sales Tax. Tenders without required earnest money or for lesser amount will be rejected as non responsive.

4. The University reserves the right to accept or reject any/all bid(s)/tender(s) in terms of Section-33 of Public Procurement Rules, 2004.

Mr.Muhammad Jamil, Addl. Director (P&S), Phone # 9019260 & 9019258

INTERNATIONAL ISLAMIC UNIVERSITY ISLAMABAD
(Purchase & Stores Section)

No. 1/3/2015-P&S-

Dated: _____


M/s _____

SUBJECT: **TENDER DOCUMENTS FOR SUPPLY OF UPS (10 KVA)**

Dear M/s,


You are invited to submit tender for supply of UPS (10 KVA) made in accordance with the specifications enclosed at **Annex-I**

2. Sealed tenders valid for a period of 3 months alongwith Earnest Money @ 2% of the total value of tender in the shape of Call Deposit/Bank Draft in the name of "International Islamic University, Islamabad" must reach the undersigned on or before **21-03-2017** at 10.30 a.m. The tenders will be opened on the same day at 11:00 a.m. in the presence of the bidders/their representatives who may like to attend the opening.
3. Tenders received after the due date and time will not be entertained.
4. Amendments/alteration/cutting and overwriting etc. in the tender must be signed in full by the person who has signed the tender. Changes or revisions in rates after the opening of tender will not be allowed.
5. Tenders must be in a sealed cover and on the envelope, it must be written in bold letter "**TENDER FOR SUPPLY OF UPS (10 KVA)**" to be opened on **21-03-2017** & should be sent in the name of Addl. Director (P&S), International Islamic University, Administration Block, New Campus, Sector H-10, Islamabad.
6. ***Rates quoted must be inclusive of General Sales Tax and the total cost of the items. Tender without required earnest money or for lesser amount will be treated as non responsive.***
7. The General Sales Tax Registration No. issued by the Sales Tax Department must be quoted in the bid **and the firm must be active tax payer on ATL of FBR otherwise, tender shall not be considered.**
8. The firms will have to provide the samples for assessment of quality and workmanship on demand.
9. **The successful bidder shall have to supply the required/as per specification items-wise lowest basis** on F.O.R. basis strictly within the stipulated period mentioned in the Supply Order otherwise full Earnest Money will be forfeited.
10. The University reserves the right to accept or reject any/all bid(s)/tender(s) in terms of Section-33 of Public Procurement Rules, 2004.


(Mian Rohban Yunas)
Asstt. Director-I (P&S)
Phone # 051-9019258
051-9019260

Specification of UPS 10 KVA

S.No	Item Required	Qty
1	MAESTRO UPS 10 KVA or Equivalent	1
	1. Pure Sine Wave	
	2. N+ λ Parallel Redundancy	
	3. Wide Input Voltage Range 120-276VAC	
	4. Input Current Harmonic 3%	
	5. Online Double Conversion with DSP Control	
	6. Generator compatible	
	7. Cold Start	
	8. Wide Input Frequency Range (50Hz: 45-55Hz/60Hz: 54-66Hz)	
	9. High Output Power Factor at 0.8 PF	
	10. Support Economic (ECO) Operation Mode	
	11. Advance Battery Management	
	12. Zero Transfer Time	
	13. Self Testing when UPS Start	
	14. SNMP Card	
	15. Warranty 2 Years	
	16. Lightning & Surge Protection	
	17. Short Circuit / Overload Protection	
	18. Over Charge Protection	
	19. Backup Time atleast 1.5 Hour on 80% Load	
2	Imported Battery Bank for 20 100 ah Dry Batteries	1
	Dry Batteries 12 V 100 AH (Narada/Long/Maestro) with one	
3	year Warranty	20
4	Installation with Flexible Power Cables	One Job



 10/02/16