

TENDER NOTICE

Sealed Bids are invited for supply of **DIESEL GENERATORS** for International Islamic University, Islamabad.

2- Tender documents can be downloaded from www.ppra.org.pk and www.iiu.edu.pk. Tender fee of **Rs.1000/-** (Non-refundable) will be deposited alongwith bid/tender in shape of Call Deposit/Bank Draft in favour of IIUI.

3- Tenders valid for a period of 03 months on F.O.R. basis along with earnest money @ 2% of total value of tender (refundable) in the shape of Call Deposit/Bank Draft in the name of International Islamic University, Islamabad, must reach the undersigned on or before **08-10-2015 at 10:30 a.m.** which will be opened on the same date at **11:30 a.m.** in presence of the bidders/their representatives who may like to attend the opening ceremony. The GST Registration No. issued by the Sales Tax Department must be mentioned in the bid, otherwise, tender shall not be considered. Price quoted must clearly show whether it is inclusive or exclusive of General Sales Tax. Tenders without required earnest money or for lesser amount will be rejected as non responsive. For any query contact **N.9019293**

4- The University reserves the right to accept or reject any/all bid(s) in terms of Section-33 of Public Procurement Rules, 2004

Asif Munir Babar, Addl. Director (P&S)

Contact No.9019261

Price of Tender Document

Rs. 1000/-

No. 4/3/2015 -P&S-

Dated _____

M/s _____

SUBJECT: **TENDER DOCUMENTS FOR DIESEL GENERATORS FOR IIUI**

Dear M/s,

You are invited to submit tender for supply of **DIESEL GENERATORS** accordance with technical specifications as per **Annexed "A"**

2. Sealed tenders valid for a period of 3 months alongwith Earnest Money @ 2% of the total value of tender in shape of Call Deposit/Security Receipt in the name of "International Islamic University, Islamabad" **must reach the undersigned on or before 08-10-2015 upto 10:30 hours.** The tenders will be opened on the same day at **11:30 a.m.** in the presence of the bidders/their representatives who may like to attend the opening.
3. Tenders received after the due date and time will not be entertained.
4. Tenders must be in a sealed envelope, it must be written in bold letter **"DIESEL GENERATORS"** to be opened on **08-10-2015** & should be sent in the name of Addl. Director (P&S), International Islamic University, Islamabad
5. Bid (s) without required earnest money or for lesser amount will be rejected as non responsive.
6. The successful bidder shall have to supply the required items on F.O.R. basis strictly within the stipulated period mentioned in the Supply Order otherwise Earnest Money will be forfeited.
7. Please see the detail of Terms & Conditions of the tender at page **No.3& 4.**



(MUHAMMAD NASIR)

Assistant Director-III (P &S)

Phone # 9019293

GENERAL TERMS AND CONDITIONS FOR PROCUREMENT OF 03 NOS. 200KVA DIESEL GENERATOR FOR THE NEWLY CONSTRUCTED FEMALE HOSTELS.

Terms & Conditions:

1. The bidder should submit a single package containing two separate sealed envelopes. One envelope should contain the Pre-qualification/Technical proposal and the other envelope should contain the financial proposal. Both showing the tender enquiry No _____ and marked as **“PRE-QUALIFICATION/TECHNICAL PROPOSAL”** and **“FINANCIAL PROPOSAL”** respectively.
2. The IIU's requirements/Technical specifications are given as Annexed “A”
3. The firm should be registered with sale Tax and Income Tax Department (attach copy of Registration certificate). Quote Rates, GST and other taxes separately and must be an active Tax Payer.
4. The bidder must be a Manufacturer or Authorized Partner/Dealer.
5. The bid must be on prescribed Performa issued by IIU. No letter Head, Photocopy will be accepted.
6. Affix Company Seal on all documents dully signed by the authorized person.
7. The firm should have a minimum of 10(ten) years experience of similar assignment(s) and should have proper workshop facility in Rawalpindi/Islamabad along with detail of Technical man power in their workshop.
8. The bid validity period is required to be three (03) months, starting from the date of opening of the bids.
9. The supplier will have to be commissioned the required Diesel Generators within four (04) months period, starting from the issuance of supply order.
10. The bidder must have supplied at least twenty (20) sets of the same capacity or above Gen set to any known government agency in last 05 years. Please provide name and address of the organization and contact detail for verification.
11. The firm should not be involved in any kind of litigation and not be a black listed any public or private sector organization.

12. The proposal should have over writing or cutting. If the Technical proposal of any firm does not fulfill any of aforementioned criteria then they may consider as disqualified and their financial bids shall be returned un-opened.
13. The contract will be awarded to the lowest evaluated bidder.
14. Payment of the bills shall be made subject to the deduction of mandatory government Taxes/Levies.
15. The University reserves the right to accept or reject any/all bid(s) in terms of Section-33 of Public Procurement Rules, 2004
16. An affidavit of Rs.200/- (non judicial Stamp) that the Firm is not black listed in any government department.



Sr. #	Description	Qty	Rate with GST	Rate with out GST	Amount
01	<p>Supply and Installation of 200 KVA Diesel Generator Set with following Specification:</p> <p>Prime power 200 KVA/160KW</p> <p>Power factor 0.8 lagging</p> <p>Voltage (+5%) 400/230 Volts</p> <p>Frequency 50 hertz</p> <p>Speed 1500 rpm</p> <p>Temperature 40 Degree Celsius</p> <p>Fuel Tank built-in Skid at-least 8 hours operation</p> <p>Canopy Standard (Local/Foreign)</p> <p>AMF Panel Suitable for 200 KVA Genset.</p> <p>Phase 03 Phase</p> <p>Engine ISO 3046/BS 5514/DIN 6271</p> <p>Volvo, Cummins, Perkins or</p> <p>Equivalent Western European/ U.S Made.</p> <p>Alternator IEC-60034-1 suitable for above</p> <p>DG Set</p> <p>ATS Panel Suitable for 200 KVA Generator</p> <p>Accessories</p> <p>Generator Metering Volt Meter, Ampere Meter, Phase</p> <p>Selector Switch, Frequency Meter,</p> <p>Generator Set Monitoring D.C Voltage, Coolant Temperature,</p> <p>Oil Pressure, Hours Run Time, RPM, Controls, Start/Stop Control,</p> <p>Voltage Control,</p> <p>Standard Indications Low Oil Pressure Shut Down, High Coolant Temperature Shut Down</p> <p>Emergency stop Shut Down</p>	03			
02	Synchronization of 3x200 KVA DG Sets (LOAD SYNC)	01			
03	<p>RCC Foundation 18" Depth and Earthling.</p> <p>The rates should include all foundations (Generators, ATS Panels etc)</p>	03			
04	Cable				
	i. Supply and Installation of Control Cable 2.5mm ² , 12 core	50			
	ii. Supply and Installation of 150mm ² single core (Pakistan Cable, Pioneer Cable, AGE Cable or equivalent)	600			