

INTERNATIONAL ISLAMIC UNIVERSITY ISLAMABAD
TENDER NOTICE

Sealed Bids are invited from reputable quality firms/suppliers **registered with GST Deptt. and must be on active tax payer list (ATL)** for supply of **Generator (10 KVA) and UPS (5 KVA)** for International Islamic University, Islamabad.

2. Tender documents can be downloaded from **www.ppra.org.pk** and **www.iiu.edu.pk**. Tender fee of Rs.500/- each (Non-refundable) will be deposited alongwith bid/tender in the shape of Call Deposit/Bank Draft in favour of IIUI.

3. Tenders valid for a period of 03 months on F.O.R. basis along-with earnest money @ 2% of the total value of tender (refundable) in the shape of Call Deposit/Bank Draft in the name of International Islamic University, Islamabad, must reach the undersigned on or before **13-09-2017 at 10:30 a.m.** which will be opened on the same date at **11:00 a.m.** in the presence of the bidders/their representatives who may like to attend the opening ceremony. The GST Registration No. issued by the Sales Tax Department must be mentioned in the bid, otherwise, tender shall not be considered. Price quoted must inclusive of General Sales Tax. Tenders without required earnest money or for lesser amount will be rejected as non responsive.

4. The University reserves the right to accept or reject any/all bid(s)/tender(s) in terms of Section-33 of Public Procurement Rules, 2004.

Mr.Mian Rohban Yunus, Asstt. Director (P&S), Phone # 9019260 & 9019258

Mian Rohban Yunus
Asstt. Director (P&S)
Phone # 9019260
9019258

INTERNATIONAL ISLAMIC UNIVERSITY ISLAMABAD
(Purchase & Stores Section)

No. 1/3/2015-P&S-

Dated: _____


M/s _____

SUBJECT: **TENDER DOCUMENTS FOR SUPPLY OF GENERATOR (10 KVA) AND UPS (5 KVA)**

Dear M/s,

You are invited to submit tender for supply of Generator (10 KVA) and UPS (5 KVA) made in accordance with the specifications enclosed at **Annex-I**

2. Sealed tenders valid for a period of 3 months alongwith Earnest Money @ 2% of the total value of tender in the shape of Call Deposit/Bank Draft in the name of "International Islamic University, Islamabad" must reach the undersigned on or before **13-09-2017** at 10.30 a.m. The tenders will be opened on the same day at 11:00 a.m. in the presence of the bidders/their representatives who may like to attend the opening.
3. Tenders received after the due date and time will not be entertained.
4. Amendments/alteration/cutting and overwriting etc. in the tender must be signed in full by the person who has signed the tender. Changes or revisions in rates after the opening of tender will not be allowed.
5. Tenders must be in a sealed cover and on the envelope, it must be written in bold letter "**TENDER FOR SUPPLY OF GENERATOR (10 KVA) AND UPS (5 KVA)**" to be opened on **13-09-2017** & should be sent in the name of Asstt. Director (P&S), International Islamic University, Administration Block, New Campus, Sector H-10, Islamabad.
6. ***Rates quoted must be inclusive of General Sales Tax and the total cost of the items. Tender without required earnest money or for lesser amount will be treated as non responsive.***
7. The General Sales Tax Registration No. issued by the Sales Tax Department must be quoted in the bid **and the firm must be active tax payer on ATL of FBR otherwise, tender shall not be considered..**
8. The firms will have to provide the samples for assessment of quality and workmanship on demand.
9. **The successful bidder shall have to supply the required/as per specification items-wise lowest basis** on F.O.R. basis strictly within the stipulated period mentioned in the Supply Order otherwise full Earnest Money will be forfeited.
10. For any technical query please contact Mr. Muhammad Nisar, Deputy Director (Electrical) Telephone # Office 9019444 or 0322-2646189
11. The University reserves the right to accept or reject any/all bid(s)/tender(s) in terms of Section-33 of Public Procurement Rules, 2004.


(Mian Rohban Yunas)
Asstt. Director-I (P&S)
Phone # 051-9019258
051-9019260

1. GENERATOR (10 KVA):

| |
|---|
| <p>Supply, Installation Testing & Commissioning of 10 KVA (Prime) Diesel Generator Set with the following Specification:</p> <ul style="list-style-type: none">i. Prime Power: 10 KVA/8 KWii. Power Factor: 0.8 Laggingiii. Voltage ($\pm 5\%$): 400/230 Voltsiv. Phase: 3 . . .v. Frequency: 50 Hzvi. Speed: 1500 rpmvii. Temperature: 40°Cviii. Fuel Tank: Built-in Skid for at-least 8 Hours operation on full loadix. Canopy: Standard Acoustic & Weather Proof Imported/Foreignx. ATS/AMF Panel: with MOR suitable for 10 KVA DG Set with Deep-Sea Modulexi. Engine: Western European/USA Made like Volvo, Cummins, Perkins or Equivalentxii. Alternator: Western European/USA Made like Stamford or Equivalentxiii. Coupling: The Generator Set shall be coupled in Western Europe/USAxiv. Accessories: Volt Meter, Ampere Meter, Phase Selector Switch, Frequency Meter, Generator Set Monitoring DC Voltage, Coolant Temperature, Oil Pressure , Hours Run Time, RPM Controls, Start/Stop Control, Voltage Controlxv. Standard Indicators: Low oil Pressure Shut Down, High Coolant Temperature Shut Down, Emergency Shut Downxvi. Control Cables: All control Cables required shall be included in the price. <p>Standard Civil Works (RCC Foundation Pad minimum 18" Depth minimum 12" above ground including Earthing Works & Cabling.</p> |
|---|

2. UPS (5KVA):

| |
|---|
| <p>Supplying, Installation, Testing & Commissioning of UPS (5 KVA) with the following specification:</p> <p>Make: APC or Equivalent</p> <p>Waveform: Pure Sine Wave</p> <p>High Output Power Factor: 0.9 P.F</p> <p>Backup Time: At least 1.5 Hours on 80% Load</p> <p>Protections: Short Circuit/ Overload/Over charge</p> <p>Transfer Time: 0 m second</p> <p>Generator Compatible</p> <p>Self Testing when UPS Start</p> <p>Wide Input Voltage Range: 120-270VAC</p> <p>Wide Input Frequency Range: 50Hz: 45-55Hz/ 60Hz: 54-66Hz</p> <p>Warranty: 02 Years</p> |
|---|